

# Certificate

**Applicant:** SolarEdge Technologies  
1 HaMada Street  
Herzeliya 4673335  
Israel

**Product:** PV Inverter

**Model:** SE25K, SE27.6K

**Intended use:**

Automatic disconnection device with three-phase mains surveillance for photovoltaic systems with a three-phase parallel coupling via an inverter in the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverter.

**Applied standards and guidelines:**

**EN 50438:2013**

Requirements for the connection of micro-generators in parallel with public low-voltage distribution networks.

Default interface protection settings:

Parameter	Max. disconnection time	Min. operate time	Trip value
Over voltage stage 1	3s	-	230V + 10% 10min mean value
Over voltage stage 2	0,2s	0,1s	230V + 15%
Under voltage	1,5s	1,2s	230V – 15%
Over frequency	0,5s	0,3s	52Hz
Under frequency	0,5s	0,3s	47,5Hz

The safety concept of an aforementioned representative product corresponds at the time of issue of this certificate to the valid safety specifications for the specified use in accordance with regulations.

**Report No:** 15PP010-09

**Certificate No:** 15-122-01

**Date of issue:** 2015-07-22



**Andreas Aufmuth**  
Certification Department

