



Compliance Statement

Screened Category 6 ISO/IEC, EN & /TIA/EIA Communication Cable

Emitter Identification K/EMITERNET-FTPCAT6

Category 6, Overall Foil Screened
100 Ω , 4 Twisted Pairs, 24 AWG, Flame Retardant, Copper Cable

Emitter Sp.zo.o
ul Porcelanova 27
40-241 Katowice, Poland

Compliance Statement No. 111664

This Screened ISO/IEC, EN & TIA/EIA Communication Cable has been tested by 3P Third Party Testing and complies with the Category 6 performance requirements of 2nd edition ISO/IEC Generic Cabling Standard 11801, CENELEC Generic Cabling Standard EN 50173-1:2007, ANSI/TIA Generic Cabling Standard 568-C.2 and 2nd edition IEC Cable Standard 61156-5, and the requirements of CENELEC Cable Standard EN 50288-5-1. Flame Retardancy is verified according to IEC 60332-1-2. The cable has EMC Performance Rating 8. The Compliance Statement may be suspended or withdrawn if cable fails to pass a Maintenance of Qualification Testing performed at 6 or 12 month intervals.

Hoersholm, 17th June 2010

A handwritten signature in blue ink, appearing to read "Ole Lambertsen", written over a horizontal line.

Ole Lambertsen
Test Responsible

Hoersholm, 17th June 2010

A handwritten signature in blue ink, appearing to read "Poul Villien", written over a horizontal line.

Poul Villien
Coordinating Manager